

305 S. Powell Pkwy.  
Anna, TX 75409  
972.924.2143  
[firecad@annatexas.gov](mailto:firecad@annatexas.gov)



*"Providing quality service to our neighbors  
through Dedication, Training, and Professionalism"*

## **NFPA 13D - POLICY STATEMENT**

**EFFECTIVE DATE: 11/01/2023**

Under the requirements set forth by the Anna Fire Marshal's Office as the designated Authority Having Jurisdiction (AHJ) regarding all fire code interpretations and enforcement, the following policy statement hereby applies to the *2015 International Fire Code* as adopted by the City of Anna: specifically, *Section 903.3.1.3 NFPA 13D sprinkler systems*.

All Group R duplexes, townhomes, and townhouses shall require the installation of an automatic sprinkler system throughout in accordance with NFPA 13D and the requirements of *Section 903.3.1.3*. Installations must be permitted and comply with the requirements and policies of the Anna Fire Marshal's Office, City of Anna ordinance, and state law.

Respectfully,

A handwritten signature in black ink, appearing to read "Ray Isom". The signature is written in a cursive, flowing style.

Ray Isom  
Fire Chief / Fire Marshal